

Weakley County Board of Education



Monitoring:

Descriptor Term:

District Water Testing

Descriptor Code:

3.212

Issued Date:

8/3/2023

1 *General*

2

3 All district facilities built before January 1, 1998 shall be tested for lead in drinking water every
4 two (2) years.¹

5

6 The district shall develop appropriate administrative procedures to facilitate this testing and
7 address and necessary corrective action.

8

9 **RESPONSE TO TESTING RESULTS²**

10

11 If test results show that lead levels exceed fifteen parts per billion (15 ppb) but are below twenty
12 parts per billion (20 ppb), that building shall conduct lead level tests on an annual basis. This
13 shall continue until tests show that the lead levels are under fifteen parts per billion (15 ppb).

14

15 If test results show that lead levels equal or exceed twenty parts per billion (20 ppb), the school
16 shall immediately remove the drinking water source from service. The drinking water source
17 shall not be available for use until retesting confirms the water lead level does not exceed twenty
18 parts per billion (20 ppb). If corrective action is taken, retesting shall occur within ninety (90)
19 days.

20

21 The Director of Schools/designee shall notify the appropriate authorities within twenty-four (24)
22 hours of a test result showing that lead levels equal or exceed twenty parts per billion (20 ppb).
23 Parent(s)/guardian(s) shall be notified within five (5) business days of such test result.

24

25 Additionally, if the result of a lead level test is equal to or exceeds twenty parts per billion (20
26 ppb), the Director of Schools/designee shall submit an online form through the Formstack site.

¹ TCA 49-2-133

² Ibid.